

**Report for the Third Quarter of 2025 pursuant to the Consent Decree entered in
United States v. Westchester Joint Water Works, 24 Civ. 4783 (S.D.N.Y.)**

This report summarizes the work undertaken to comply with the consent decree from July 1, 2025 through September 30, 2025 and provides the information required by paragraphs 70 and 71 of the consent decree.

The following are actionable items, relative to paragraph 71.a:

VII. INJUNCTIVE RELIEF: FILTRATION PLANT

23. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

24. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

25. Subject to Paragraph 33 and Section XIII (Force Majeure), by March 8, 2025, WJWW shall secure all necessary local, state, and federal final approvals and permits (excluding NYSDOH approvals and the Contractor Permits) for the Filtration Plant....

Compliance previously satisfied and described in Report for the First Quarter of 2025.

The following should be noted:

- On September 24, 2025, a fully executed Application For Building Permit signed by Yonkers Contracting Company was submitted to the Town/Village of Harrison and is under review at this time.
- On August 26, 2025, the New York State Department of Environmental Conservation ("NYSDEC") accepted the Interim Remedial Measure (IRM) Work Plan for the Rye Lake Water Filtration Plant (WFP) project, which was submitted by WJWW to the NYSDEC on June 12, 2025. Soil, groundwater, and soil vapor sampling has been performed in accordance with the IRM Work Plan, and WJWW is awaiting results of all sampling.

26. Compliance previously satisfied and described in Report for the First Quarter of 2025.

27. Compliance previously satisfied and described in Report for the Second Quarter of 2025.

28. By September 2, 2025, WJWW shall award the contract to construct the Filtration Plant.

- On August 12, 2025, the contract was awarded to Yonkers Contracting Company.

29. By August 4, 2025, WJWW shall also identify and submit to EPA and the State a proposed schedule of Additional Milestones ...

- On August 4, 2025, a proposed schedule of Additional Milestones was submitted to the EPA and the State. As agreed, a final version will be submitted to the EPA and the State on or before November 3, 2025, incorporating adjustments based on contractor input and evolving project conditions, if any.

34. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

VIII. INJUNCTIVE RELIEF: INTERIM MEASURES

43. WJWW shall remain in compliance with the TTHM and HAA5 monitoring requirements, methodology requirements, and reporting requirements of the Stage 2 DBPR.

WJWW continues to comply.

44. WJWW shall conduct monitoring quarterly for TTHM and HAA5 in accordance with 40 C.F.R. § 141.621(a) and WJWW's approved monitoring plan...

WJWW continues to comply.

45. WJWW must comply with all public notice requirements specified in 40 C.F.R. Part 141, Subpart Q, for any TTHM or HAA5 MCL violation that occurs after the Effective Date of this Consent Decree.

There have been no violations since the Effective Date of the Consent Decree.

46. In addition to routine reporting to the WCDOH, WJWW shall submit to EPA the results of the TTHM and HAA5 monitoring required by this subparagraph...

A copy of the 2025 3rd Quarter TTHM and HAA5 Sampling Report previously provided to the WCDOH, under cover letter dated September 9, 2025, is annexed as Appendix A. These results have been posted on the WJWW Filtration Plant microsite <https://wjwwfiltration.org/>

47. If the WJWW Water System violates a TTHM or HAA5 MCL, WJWW must submit a report to EPA, WCDOH, and NYSDOH ...

There have been no violations since the Effective Date of the Consent Decree.

48. At all times after the Effective Date during the duration of this Decree, WJWW must implement the flushing protocol attached hereto as Appendix B...

The flushing protocol was implemented in 2020 and has continued uninterrupted to date and will continue.

50. WJWW must report results from the source water monitoring to EPA, NYSDOH and WCDOH no later than 10 Days after the end of the first month following the month when the sample is collected. Within 14 Days after WJWW has submitted the results of the source monitoring to EPA, NYSDOH and WCDOH, WJWW shall post the results of the monitoring on its website.

LT2 Second Round Source Water Monitoring Sample Results for July, August and September 2025, were submitted to the EPA, the NYSDOH, and the WCDOH on August 7, 2025, September 8, 2025, and October 8, 2025, respectively. These results have been posted on the WJWW Filtration Plant microsite <https://wjwwfiltration.org/>

53. CT Calculations. For each day the WJWW water system is in operation, the WJWW shall calculate the total inactivation ratio pursuant to the provisions of 40 C.F.R. §§ 141.74(b)(3) and (4). WJWW shall report to EPA, NYSDOH, and WCDOH the information listed at 40 C.F.R. § 141.75(a)(2) monthly, within 10 Days after the end of each month.

Water System Operating Reports for July, August, and September 2025, were submitted to the EPA and the NYSDOH on August 8, 2025, September 9, 2025, and by October 8, 2025, and to the WCDOH on August 7, 2025, September 8, 2025, and by October 7, 2025, respectively.

55. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

57. WJWW shall include a statement in its annual Drinking Water Quality Report until compliance with the deadlines in Section VII is achieved...

On May 30, 2025, the latest Annual Drinking Water Quality Report, which includes such statement, was posted on WJWW website: <https://www.wjww.com/>

58. Prior to commencing construction of the Filtration Plant, WJWW shall establish and maintain a website or a webpage on its website...

The required information is available to the public at the project website: <https://wjwwfiltration.org/>

X. SUPPLEMENTAL ENVIRONMENTAL PROJECT

61. WJWW shall implement a Supplemental Environmental Project (“SEP”) in accordance with this Section X and the SEP Memo annexed as Appendix D. WJWW shall spend no less than \$900,000 to implement the SEP. The SEP shall be completed within 54 months after the Effective Date in accordance with the schedule of milestones set forth in Appendix D. The SEP shall be comprised of the project to improve the quality of storm water entering the Kensico Reservoir described in the SEP Memo annexed as Appendix D.

- On December 20, 2024, WJWW submitted its Preliminary Design Report for the SEP to NYCDEP for its review. A copy of the Preliminary Design Report was annexed to the Report for the Fourth Quarter of 2024.
- On January 13, 2025, NYCDEP reviewed WJWW’s Preliminary Design Report dated December 20, 2024, and found the concept acceptable.

64. SEP Completion Report. No later than 56 months from the Effective Date, Defendants shall submit a SEP Completion Report to DOJ, EPA and the State in accordance with Section XVIII (Notices). The SEP Completion Report shall contain the following information:

c. an itemized list of all eligible SEP costs expended;

- It can be noted that WJWW has expended \$28,310 to date.

VI. CIVIL PENALTY

17. In addition, WJWW shall spend a total of at least \$6,800,000 on two water quality benefit projects (the “Benefit Projects”). ... The Benefit Projects are: (i) a new water main to the Quarry Heights neighborhood of the Town of North Castle (the “Quarry Heights Project”), as described in Appendix A, and (ii) the establishment of a Lead Service Line Replacement Program (the “Lead Service Line Replacement Program”).

- With regard to 17.a, WJWW has deposited \$1,100,000 into a segregated account to be used exclusively for the Quarry Heights Project.
- On May 19, 2025, WJWW deposited \$5,700,000 into a segregated account to be used exclusively for the Lead Service Line Replacement Program. On August 21, 2025, the proposed Lead Service Line Replacement Program was approved by the State.

18. WJWW shall provide the State with an accounting of the amount spent on the Benefit Projects within 60 Days of project completion.

- Neither the Quarry Heights Project nor the Lead Service Line Replacement Program has been completed. It can be noted that the Quarry Heights Project is approximately 95% complete with the project now expected to be fully completed by Spring 2026.
- It can be noted that WJWW has expended approximately \$1,043,113 on the Quarry Heights Project to date, and has expended \$0 on the Lead Service Line Replacement Program to date.

I hope that the above provides a satisfactory Quarterly Report. Should you require any additional information, details or clarification, please let me know.

73. Certification

I certify under penalty of perjury that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I have no personal knowledge that the information submitted is other than true, accurate, and complete. I am aware that there are significant penalties for knowingly submitting false information, including the possibility of fine and imprisonment for knowing violations.

Dated: October 15, 2025



Paul Kutzy, P.E.
Manager
Westchester Joint Water Works
1625 Mamaroneck Ave.
Mamaroneck, NY 10543
Office: 914-698-3500 x 612
Fax: 914-381-4241
pkutzy@wjww.com

APPENDIX A

2025 Q3 TTHM & HAA5 Sampling Report



WESTCHESTER JOINT WATER WORKS

1625 Mamaroneck Avenue
Mamaroneck, New York 10543
www.wjww.com

Telephone: (914) 698-3500
Fax: (914) 381-4241
Fax: (914) 381-0349

September 9, 2025

Ms. Nawrin Anwar
Senior Engineer
Bureau of Environmental Quality
Westchester County Department of Health
25 Moore Avenue
Mt. Kisco, NY 10549

Dear Ms. Anwar,

I have attached the Westchester Joint Water Works 2025 3rd quarter THM and HAA5 results.

If you have any questions, feel free to contact me. Thank you.

Very truly yours,

Daniel Pirrone
Chief Water Treatment Pl. Operator IB

Bureau of Environmental Quality
Public Water Supply Stage II Trihalomethanes (THM) Sampling Report

Westchester Joint Water Works
Name of Public Water Supply

2025
3rd Quarter Period

Date of Sampling: 7/24/2025
Time of Sampling: 0615 Through 1025

Trihalomethanes (THM)	Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Bromodichloromethane (ug/L)	3.37	2.57	4.47	4.33	3.83	1.72	2.99	3.52	////////	////////	////////	////////	////////	////////	////////	////////
Bromoform (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////////	////////	////////	////////	////////	////////	////////	////////
Chloroform (ug/L)	39.90	24.40	58.40	48.60	42.70	13.80	27.50	38.60	////////	////////	////////	////////	////////	////////	////////	////////
Dibromochloromethane(ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////////	////////	////////	////////	////////	////////	////////	////////
									////////	////////	////////	////////	////////	////////	////////	////////
									////////	////////	////////	////////	////////	////////	////////	////////
									////////	////////	////////	////////	////////	////////	////////	////////
									////////	////////	////////	////////	////////	////////	////////	////////
Total Trihalomethanes (ug/L)	43.270	26.970	62.870	52.930	46.530	15.520	30.490	42.120								
Total Trihalomethanes (mg/L)	0.043	0.027	0.063	0.053	0.047	0.016	0.030	0.042								

Sampling Location #	Address of Sampling Location / (Sample Collection Point)	<u>3rd Quarter 2025</u>		<u>2nd Quarter 2025</u>	<u>1st Quarter 2025</u>	<u>4th Quarter 2024</u>	<u>Current Four Quarter Rolling Average</u>
		Cl2 Residual (mg/L)	THM (mg/L)	THM (mg/L)	THM (mg/L)	THM (mg/L)	THM (mg/L)
1	250 Westchester Ave (Hydrant P-14)	0.60	0.043	0.038	0.037	0.053	0.043
2	12 Beverly Rd (Hydrant No. 3577)	0.95	0.027	0.022	0.026	0.024	0.025
3	Hyatt House 101 Corporate Park Drive (Kitchen Sink)	0.62	0.063	0.024	0.020	0.034	0.035
4	1490 Old Orchard Rd (Hydrant No. 6001)	0.28	0.053	0.059	0.026	0.057	0.049
5	2 Lincoln Lane (Hydrant No. 3883)	0.82	0.047	0.024	0.012	0.033	0.029
6	Booster Station 4195 Purchase St (Lab Sink)	1.30	0.016	0.016	0.012	0.019	0.016
7	Staples Boston Post Rd (Bathroom Sink)	0.06	0.030	0.025	0.014	0.028	0.024
8	66 Bellevue Ave (Hydrant No. 3179)	0.67	0.042	0.028	0.013	0.030	0.028

Lab Performing Analysis: Westchester County Dept of Labs

Samples Approved 9/7/2025

Rolling Average MCL: 0.08 mg/L

Bureau of Environmental Quality
Public Water Supply Stage II Haloacetic Acids (HAA5) Sampling Report

Westchester Joint Water Works

Name of Public Water Supply

2025
3rd Quarter Period

Date of Sampling: 7/24/2025
Time of Sampling: 0615 Through 1025

Haloacetic Acids (HAA5)	Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Dibromoacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////////	////////	////////	////////	////////	////////	////////	////////
Dichloroacetic Acid (ug/L)	6.91	13.90	3.25	2.60	14.00	1.41	12.80	2.46	////////	////////	////////	////////	////////	////////	////////	////////
Monochloroacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////////	////////	////////	////////	////////	////////	////////	////////
Trichloroacetic Acid (ug/L)	24.20	18.80	1.17	26.40	28.50	2.94	20.30	25.70	////////	////////	////////	////////	////////	////////	////////	////////
Monobromoacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////////	////////	////////	////////	////////	////////	////////	////////
									////////	////////	////////	////////	////////	////////	////////	////////
Total Haloacetic Acids (ug/L)	31.110	32.700	4.420	29.000	42.500	4.350	33.100	28.160								
Total Haloacetic Acids (mg/L)	0.031	0.033	0.004	0.029	0.043	0.004	0.033	0.028								

Sampling Location #	Address of Sampling Location / (Sample Collection Point)	<u>3rd Quarter 2025</u>	<u>2nd Quarter 2025</u>	<u>1st Quarter 2024</u>	<u>4th Quarter 2024</u>	<u>Current Four Quarter Rolling Average HAA5 (mg/L)</u>
		<u>C12 Residual (mg/L)</u>	<u>HAA5 (mg/L)</u>	<u>HAA5 (mg/L)</u>	<u>HAA5 (mg/L)</u>	
1	250 Westchester Ave (Hydrant P-14)	0.60	0.031	0.042	0.028	0.033
2	12 Beverly Rd (Hydrant No. 3577)	0.95	0.033	0.045	0.041	0.037
3	Hyatt House 101 Corporate Park Drive (Kitchen Sink)	0.62	0.004	0.040	0.033	0.028
4	1490 Old Orchard Rd (Hydrant No. 6001)	0.28	0.029	0.018	0.038	0.027
5	2 Lincoln Lane (Hydrant No. 3883)	0.82	0.043	0.042	0.028	0.037
6	Booster Station 4195 Purchase St (Lab Sink)	1.30	0.004	0.035	0.032	0.025
7	Staples Boston Post Rd (Bathroom Sink)	0.62	0.033	0.037	0.026	0.030
8	66 Bellevue Ave (Hydrant No. 3179)	0.67	0.028	0.048	0.027	0.034

Lab Performing Analysis: Westchester County Dept of Labs

Samples Approved 9/7/2025

Rolling Average MCL: 0.06 mg/L

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : P-14 HYDRANT
250 WESTCHESTER AVE
W. HARRISON, NY

Received By : GT
Bottle No : K3229 30 31 FB0212 T10

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 07/24/2025 AT 09:50:00
Submitted On : 07/24/2025 AT 10:38:00
PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.40
Free Cl2 : 0.60 Residual Cl2 :
Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment : TEMP: 19.7
pH: 7.40 3RD QUARTER

addt'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	3.37		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Chloroform	39.9		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BB13342

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,2-Dichloroethene	Not Analyzed		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ	CL	ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/30/2025	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. BB13342

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier: This compound recovered below the acceptable QC criteria in continuous calibration verification. Established low bias on <LOQ results renders the analytical data suspect.

GZ 8/20/2025

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dichloroacetic Acid	6.91		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/07/2025	GZ2
EPA 552.2, Re\	Trichloroacetic Acid	24.2		ug/L	1.00	08/07/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

Sample No. **BB13340**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3577
12 BEVERLY RD
HARRISON, NY

Received By : GT
Bottle No : K3292 93 94 FB0212 T0013

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 07/24/2025 AT 09:15:00
Submitted On : 07/24/2025 AT 10:38:00
PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.60
Free Cl2 : 0.95 Residual Cl2 :
Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment : TEMP: 19.5
pH: 7.60 3RD QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	2.57		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Chloroform	24.4		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. **BB13340**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,2-Dichloroethene	Not Analyzed		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ	CL	ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/30/2025	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 2 of 3

Sample No. BB13340

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

This sample had a pH of 3. The method stipulated preservation requirement is a pH <2. This method deviation will render the data unsuitable for regulatory reporting purposes.

"CL" qualifier: This compound recovered below the acceptable QC criteria in continuous calibration verification. Established low bias on <LOQ results renders the analytical data suspect.

DN/GZ/RH 8/20/2025

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dichloroacetic Acid	13.9		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/07/2025	GZ2
EPA 552.2, Re\	Trichloroacetic Acid	18.8		ug/L	1.00	08/07/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By Robert Hilbrandt Jr.

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYATT HOUSE
101 CORP PARK DRIVE
HARRISON, NY

Received By : GT
Bottle No : K3307 08 09 FB0212 T916

Collection Point : SAMPLE PORT STATION

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 07/24/2025 AT 09:28:00
Submitted On : 07/24/2025 AT 10:38:00

PWS No. : 5903435

Type Descriptor : 022 **Source ID :** 000

pH : 7.50

Free Cl2 : 0.62

Residual Cl2 :

Sample chilled on arrival ? : YES

Sample Type : POT_DW

Comment : TEMP: 20.6

pH: 7.50 3RD QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	4.47		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Chloroform	58.4		ug/L	1.00	08/01/2025	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By Robert Hilbrandt Jr.

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 1 of 3

Sample No. **BB13341**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,2-Dichloroethene	Not Analyzed		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ	CL	ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/30/2025	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 2 of 3

Sample No. BB13341

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Chloroform exceeded the calibration range. Sample was reanalyzed with a 1:2 dilution.

"CL" qualifier: This compound recovered below the acceptable QC criteria in continuous calibration verification. Established low bias on <LOQ results renders the analytical data suspect.

DN/GZ 8/20/2025

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dichloroacetic Acid	3.25		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/07/2025	GZ2
EPA 552.2, Re\	Trichloroacetic Acid	1.17		ug/L	1.00	08/07/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

Sample No. **BB13334**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #6001
1490 OLD ORCHARD ST
WEST HARRISON, NY

Received By : GT
Bottle No : K3289 90 91 FB0212 T722

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 07/24/2025 AT 10:25:00
Submitted On : 07/24/2025 AT 10:38:00
PWS No. : 5903435

Type Descriptor : 022 Source ID : 000
pH : 7.30

Free Cl2 : 0.28 Residual Cl2 :

Sample chilled on arrival ? : YES

Sample Type : POT_DW

Comment : pH: 7.30
3RD QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	4.33		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Chloroform	48.6		ug/L	1.00	08/01/2025	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. **BB13334**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,2-Dichloroethene	Not Analyzed		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ	CL	ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/30/2025	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 2 of 3

Sample No. BB13334

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Chloroform exceeded the calibration range. Sample was reanalyzed with a 1:2 dilution.

"CL" qualifier: This compound recovered below the acceptable QC criteria in continuous calibration verification. Established low bias on <LOQ results renders the analytical data suspect.

DN/GZ 8/20/2025

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dichloroacetic Acid	2.60		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/07/2025	GZ2
EPA 552.2, Re\	Trichloroacetic Acid	26.4		ug/L	1.00	08/07/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By Robert Hilbrandt Jr.

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

Sample No. **BB13339**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3883
2 LINCOLN AVE
HARRISON, NY

Received By : GT
Bottle No : K3301 02 03 FB0212 T6901

Collection Point : HYRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 07/24/2025 AT 08:50:00
Submitted On : 07/24/2025 AT 10:38:00
PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.50
Free Cl2 : Residual Cl2 :
Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment : TEMP: 20.0
pH: 7.50 3RD QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	3.83		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Chloroform	42.7		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. **BB13339**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,2-Dichloroethene	Not Analyzed		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ	CL	ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/30/2025	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 2 of 3

Sample No. **BB13339**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier: This compound recovered below the acceptable QC criteria in continuous calibration verification. Established low bias on <LOQ results renders the analytical data suspect.

GZ 8/20/2025

Haloacetic Acids

EPA 552.2, Re	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re	Dichloroacetic Acid	14.0		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/07/2025	GZ2
EPA 552.2, Re	Trichloroacetic Acid	28.5		ug/L	1.00	08/07/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 3 of 3

Sample No. **BB13335**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : PURCHASE BOOSTER
4195 PURCHASE ST
HARRISON, NY

Received By : GT
Bottle No : K3226 27 28 FB0212 T0028

Collection Point : ENTRY PT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 07/24/2025 AT 06:15:00
Submitted On : 07/24/2025 AT 10:38:00
PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.50
Free Cl2 : 1.30 Residual Cl2 :
Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment : TEMP: 18.8
pH: 7.50 TURB: .703RD QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	1.72		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Chloroform	13.8		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BB13335

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,2-Dichloroethene	Not Analyzed		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ	CL	ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/30/2025	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. BB13335

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier: This compound recovered below the acceptable QC criteria in continuous calibration verification. Established low bias on <LOQ results renders the analytical data suspect.

GZ 8/20/2025

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dichloroacetic Acid	1.41		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/07/2025	GZ2
EPA 552.2, Re\	Trichloroacetic Acid	2.94		ug/L	1.00	08/07/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By Robert Hilbrandt Jr.

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

Sample No. **BB13337**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : STAPLES
2444 BOSTON POST RD
MAMARONECK, NY

Received By : GT
Bottle No : K3250 51 52 FB0212 T0008

Collection Point : SAMPLE PORT STATION

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 07/24/2025 AT 07:45:00
Submitted On : 07/24/2025 AT 10:38:00
PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.40
Free Cl2 : 0.62 Residual Cl2 :
Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment : TEMP: 19.0
pH: 7.4 3RD QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	2.99		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Chloroform	27.5		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BB13337

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,2-Dichloroethene	Not Analyzed		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ	CL	ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/30/2025	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. BB13337

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

This sample had a pH of 3. The method stipulated preservation requirement is a pH <2. This method deviation will render the data unsuitable for regulatory reporting purposes.

"CL" qualifier: This compound recovered below the acceptable QC criteria in continuous calibration verification. Established low bias on <LOQ results renders the analytical data suspect.

DN/GZ/RH 8/20/2025

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dichloroacetic Acid	12.8		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/07/2025	GZ2
EPA 552.2, Re\	Trichloroacetic Acid	20.3		ug/L	1.00	08/07/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By Robert Hilbrandt Jr.

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 3 of 3

Sample No. **BB13338**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3179
66 BELLEVE AVE
HARRISON, NY

Received By : GT
Bottle No : K3253 54 55 FB0212 T0011

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 07/24/2025 AT 08:20:00
Submitted On : 07/24/2025 AT 10:38:00
PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.40
Free Cl2 : 0.67 Residual Cl2 :
Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment : TEMP: 20.6
pH: 7.40 3RD QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	3.52		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Chloroform	38.6		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. **BB13338**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,2-Dichloroethene	Not Analyzed		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ	CL	ug/L	2.00	07/30/2025	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/30/2025	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.500	07/30/2025	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.500	07/30/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 2 of 3

Sample No. BB13338

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier: This compound recovered below the acceptable QC criteria in continuous calibration verification. Established low bias on <LOQ results renders the analytical data suspect.

GZ 8/20/2025

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Dichloroacetic Acid	2.46		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/07/2025	GZ2
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/07/2025	GZ2
EPA 552.2, Re\	Trichloroacetic Acid	25.7		ug/L	1.00	08/07/2025	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By Robert Hilbrandt Jr.

Chief of Env. Lab Services

Date Approved : 09/07/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6463

EMAIL 9/8/2025

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3