

LT2 Second Round Source Water Monitoring Sample Results

Westchester Joint Water Works

PWS ID NY5903435

Name of Public Water Supply

Date of Sampling: 12/3/2025

Event #	Date	<u>Giardia</u>		<u>Cryptosporidium</u>		<u>E. Coli</u> <u>Per 100 ml</u>	<u>Turbidity</u> <u>NTU</u>	<u>PH</u>	<u>Temperature</u> <u>Celcius</u>
		<u>cysts/L</u>	<u>cysts/L</u>	<u>cysts/L</u>	<u>cysts/L</u>				
13	1/8/2025	0.00	0.090			1.000	1.04	7.38	5.2
14	2/5/2025**	0.00	0.000			2.0	0.750	7.05	4.4
15	3/10/2025***	0.00	0.000			1.0	0.750	7.00	5.1
16	4/2/2025	0.00	0.000			<1	0.700	6.89	8.4
17	5/7/2025	0.00	0.000			1.000	0.750	6.80	12.8
18	6/4/2025****	0.00	0.000			2.000	0.750	6.80	15.2
19	7/2/2025*****	0.00	0.000			<1	0.700	6.70	12.5
20	8/6/2025	0.00	0.000			<1	2.800	6.60	18.4
21	9/3/2025	0.00	0.000			<1	0.611	6.83	20.0
22	10/1/2025	0.00	0.000			<1	0.500	6.80	19.7
23	11/5/2025	0.00	0.000			3.100	1.800	6.60	15.0
24	12/3/2025	0.00	0.000			1.000	1.300	6.50	10.7

Lab performing analysis:

Westchester County Dept of Labs

Analytical Services, Inc

Samples Approved 12/8/25, 12/8/25, 12/24/2025

**2/5/2025 Sample was compromised. Resampled on 2/10/2025

***Sampled on 3/6/2025 not 3/5/2025 as scheduled due to WJWW operator error.

***3/6/2025 Sample was compromised. Resampled on 3/10/2025

**** 6/4/2025 Sample was compromised. Lab closed on 6/6/2025. Resampled on 6/9/2025

*****7/2/2025 sample taken on 7/1/2025 because of Lab closuer due to 4th of July Holiday

LT2 Second Round Source Water Monitoring Sample Results

Westchester Joint Water Works

PWS ID NY5903435

Name of Public Water Supply

Date of Sampling:

Event #	Date	Giardia	Cryptosporidium	E. Coli	Turbidity	PH	Temperature
		cysts/L	cysts/L	Per 100 ml	NTU		Celcius
1	1/3/2024	0.00	0.000	<1	0.820	6.52	8.2
2	2/7/2024	0.00	0.000	1.0	0.820	6.54	5.5
3	3/6/2024	0.00	0.000	1.0	0.730	6.80	7.1
4	4/3/2024	0.10	0.000	1.0	0.790	6.55	9.0
5	5/6/2024**	0.00	0.000	<1	0.770	6.68	11.6
6	6/5/2024	0.00	0.270	1.000	0.490	6.65	15.4
7	7/1/2024	0.00	0.000	1.000	0.780	6.71	18.8
8	8/7/2024	0.00	0.000	<1	0.180	6.93	19.3
9	9/4/2024	0.00	0.000	<1	0.420	6.75	19.0
10	10/2/2024	0.00	0.000	3.000	0.290	6.70	18.0
11	11/6/2024	0.00	0.000	<1	0.020	7.10	15.7
12	12/4/2024	0.00	0.000	1.000	0.740	7.65	10.3

Lab performing analysis:

Westchester County Dept of Labs

Analytical Services, Inc

Samples Approved

**5/1/2024 Sample

3/1/2024 Sample was compromised. Resampled on 3/6/2024



USEPA Method 1623.1 Analytical Report

Westchester Joint Water Works
Dan Pirrone
1625 Mamaroneck Ave.
Mamaroneck, NY 10543

Analysis Start: 12/05/2025 9:12
Analysis End: 12/08/2025 12:55
Analyst: Kyle Masters

ASI Sample ID No.: 75263-01

Method 1623.1 Batch No.: 2696 1623.1
Cryptosporidium QC ID No.: 6152
Giardia QC ID No.: 6153

Sample Information	
PWS or Client Name:	WESTCHESTER JOINT WATER WORKS
PWS ID:	NY5903435
Project or Facility Name:	WESTCHESTER JOINT-RYE LAKE PUMP STATION
Facility ID:	TP1
Sample ID / Collection Point Name:	Rye Lake
Sample Collection Point ID:	Sample pt. 1
Matrix:	Water-Raw Surface
Method:	EPA 1623.1
Analysis Type:	Field
Date / Time Collected:	12/03/2025 7:00
Turbidity (NTU):	0.8

Volume and Filtration Information	
Filter Type:	Envirocheck H1V
No of Filters Used:	1
Volume Filtered (L):	10.71
Packed Pellet Volume (mL):	0.50
Total Resuspended Concentrate Volume (mL):	5.0
Total Resuspended Concentrate Volume to IMS (mL):	5.0
Number of Sub-samples:	1
Total Sample Volume Examined (L):	10.71

Analytical Results		Matrix Spike Results		
Analyte	Total (Oo) cysts/L	Recovered (Oo) cysts/L	Spike Dose (Oo) cysts/L	Percent Recovery
<i>Giardia</i>	0.00	N/A	N/A	N/A
<i>Cryptosporidium</i>	0.00	N/A	N/A	N/A

Method: Samples processed, stained and examined using USEPA Method 1623.1: Cryptosporidium and Giardia in Water by Filtration/IMS/FA (USEPA Jan. 2012: EPA 816-R-12-001) (ASI SOP 224-9).

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : RYE LAKE STATION
900 LAKE ST
HARRISON, NY

Received By : AO
Bottle No : 71-7919

Collection Point : RAW

Collected By : GIRILLO
Collection Date : 12/03/2025 AT 07:00:00

ID of Source : NYC

Submitted On : 12/03/2025 AT 08:47:00

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435**Type Descriptor :** 002 **Source ID :** 000**pH :** 6.50**Free Cl2 :** 0.00**Residual Cl2 :****Sample chilled on arrival ? :** YES**Sample Type :** POT_DW**Comment :** TEMP: 10.7

TURB: 82

add'l Report To :

Test Description	Units	Results	Qualifier	Method
Date/Time Set		12/03/2025 AT 12:04:00		
E.Coli Enumeration by Colilert-18	per 100ml	1		Colilert-18

E = Estimated Count**Approved By** *Donald Miller***QA Officer****Date Approved :** 12/04/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6652

EMAIL 12/4/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 1 of 1

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : RYE LAKE STATION
900 LAKE ST
HARRISON, NY

Received By : AO
Bottle No : B4729

Collection Point : RAW

Collected By : GIRILLO

ID of Source : NYC

Collection Date : 12/03/2025 **AT :** 7:00:00AM

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Submitted On : 12/03/2025 **AT :** 8:47:00AM

PWS No. : 5903435

Type Descriptor : 002 **Source ID :** 000
pH : 6.50

Free Cl2 : 0.00

Residual Cl2 :

Sample chilled on arrival ? : YES

Sample Type : POT_DW

Comment : TEMP: 10.7

TURB: 82

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Inorganics							
EPA 180.1	Turbidity	1.30		NTU		0.10 12/04/2025 15:17	JLM

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Michele Matos**

QA Officer

Date Approved : 12/24/2025

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6707

EMAIL 12/24/2025

*This report shall not be reproduced, except in full, without the written consent of the
Westchester County Department of Labs and Research.*

Page 1 of 1