

**Bureau of Environmental Quality
Public Water Supply Stage II Trihalomethanes (THM) Sampling Report**

Westchester Joint Water Works
Name of Public Water Supply

2026
1st Quarter Period

Date of Sampling: 1/22/2026
Time of Sampling: 0700 Through 1120

Trihalomethanes (THM)	Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Bromodichloromethane (ug/L)	3.05	1.96	1.93	2.59	2.09	1.23	1.78	2.03	//////////	//////////	//////////	//////////	//////////	//////////	//////////	//////////
Bromoform (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	//////////	//////////	//////////	//////////	//////////	//////////	//////////	//////////
Chloroform (ug/L)	23.40	12.60	12.40	18.00	12.80	6.92	9.68	13.00	//////////	//////////	//////////	//////////	//////////	//////////	//////////	//////////
Dibromochloromethane(ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	//////////	//////////	//////////	//////////	//////////	//////////	//////////	//////////
									//////////	//////////	//////////	//////////	//////////	//////////	//////////	//////////
Total Trihalomethanes (ug/L)	26.450	14.560	14.330	20.590	14.890	8.150	11.460	15.030								
Total Trihalomethanes (mg/L)	0.026	0.015	0.014	0.021	0.015	0.008	0.011	0.015								

Sampling Location #	Address of Sampling Location / (Sample Collection Point)	<u>1st Quarter 2026</u>		<u>4th Quarter 2025</u>	<u>3rd Quarter 2025</u>	<u>2nd Quarter 2025</u>	<u>Current Four Quarter Rolling Average</u>
		Cl2 Residual (mg/L)	THM (mg/L)	THM (mg/L)	THM (mg/L)	THM (mg/L)	THM (mg/L)
1	250 Westchester Ave (Hydrant P-14)	0.43	0.026	0.038	0.043	0.038	0.036
2	12 Beverly Rd (Hydrant No. 3577)	0.84	0.015	0.022	0.027	0.022	0.022
3	Hyatt House 101 Corporate Park Drive (Kitchen Sink)	0.91	0.014	0.026	0.063	0.024	0.032
4	1490 Old Orchard Rd (Hydrant No. 6001)	0.27	0.021	0.049	0.053	0.059	0.046
5	2 Lincoln Lane (Hydrant No. 3883)	0.91	0.015	0.030	0.047	0.024	0.029
6	Booster Station 4195 Purchase St (Lab Sink)	1.06	0.008	0.014	0.016	0.016	0.014
7	Staples Boston Post Rd (Bathroom Sink)	0.63	0.011	0.024	0.030	0.025	0.023
8	66 Bellevue Ave (Hydrant No. 3179)	0.74	0.015	0.035	0.042	0.028	0.030
<u>Lab Performing Analysis: Westchester County Dept of Labs</u> Samples Approved 3/9/2026							Rolling Average MCL: 0.08 mg/L

**Bureau of Environmental Quality
Public Water Supply Stage II Haloacetic Acids (HAA5) Sampling Report**

Westchester Joint Water Works
Name of Public Water Supply

2026
1st Quarter Period

Date of Sampling: 1/22/2026
Time of Sampling: 0700 Through 1120

Haloacetic Acids (HAA5)	Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Dibromoacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////	////	////	////	////	////	////	////
Dichloroacetic Acid (ug/L)	14.40	11.70	11.20	10.60	10.30	8.79	1.78	11.70	////	////	////	////	////	////	////	////
Monochloroacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////	////	////	////	////	////	////	////
Trichloroacetic Acid (ug/L)	28.60	18.00	15.30	22.20	17.90	11.40	9.68	17.40	////	////	////	////	////	////	////	////
Monobromoacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////	////	////	////	////	////	////	////
									////	////	////	////	////	////	////	////
Total Haloacetic Acids (ug/L)	43.000	29.700	26.500	32.800	28.200	20.190	11.460	29.100								
Total Haloacetic Acids (mg/L)	0.043	0.030	0.027	0.033	0.028	0.020	0.011	0.029								

Sampling Location #	Address of Sampling Location / (Sample Collection Point)	1st Quarter 2026		4th Quarter 2025	3rd Quarter 2025	2nd Quarter 2025	Current Four Quarter Rolling Average	
		Cl2 Residual (mg/L)	HAA5 (mg/L)	HAA5 (mg/L)	HAA5 (mg/L)	HAA5 (mg/L)	HAA5 (mg/L)	
1	250 Westchester Ave (Hydrant P-14)		0.43	0.043	0.028	0.031	0.042	0.036
2	12 Beverly Rd (Hydrant No. 3577)		0.84	0.030	0.032	0.033	0.045	0.035
3	Hyatt House 101 Corporate Park Drive (Kitchen Sink)		0.91	0.027	0.032	0.004	0.040	0.026
4	1490 Old Orchard Rd (Hydrant No. 6001)		0.27	0.033	0.027	0.029	0.018	0.027
5	2 Lincoln Lane (Hydrant No. 3883)		0.91	0.028	0.036	0.043	0.042	0.037
6	Booster Station 4195 Purchase St (Lab Sink)		1.06	0.020	0.022	0.004	0.035	0.020
7	Staples Boston Post Rd (Bathroom Sink)		0.63	0.011	0.027	0.033	0.037	0.027
8	66 Bellevue Ave (Hydrant No. 3179)		0.74	0.029	0.042	0.028	0.048	0.037
Lab Performing Analysis: Westchester County Dept of Labs							Rolling Average MCL: 0.06 mg/L	
Samples Approved 3/9/2026								

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #P-14
250 WESTCHESTER AVE
W. HARRISON NY

Received By : AO JR
Bottle No : T6910 K1654 55 56 FB0352

Collection Point : HYDRANT

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 10:50:00
Submitted On : 01/22/2026 AT 11:44:00

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.30
Free Cl2 : 0.43 Residual Cl2 :

Sample chilled on arrival ? : YES

add'l Report To :

Sample Type : POT_DW

Comment : TEMP: 5.0
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	3.05		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	23.4		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC01260**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	3.02		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01260**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	1.01		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dichloroacetic Acid	14.4		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re\	Trichloroacetic Acid	28.6		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3577
12 BEVERLY RD
HARRISON, NY

Received By : AO JR
Bottle No : T922 K1705 06 07 FB0352

Collection Point : HYDRANT

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 10:15:00
Submitted On : 01/22/2026 AT 11:44:00

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.60
Free Cl2 : 0.84 Residual Cl2 :

Sample chilled on arrival ? : YES

add'l Report To :

Sample Type : POT_DW

Comment : TEMP: 6.2
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	1.96		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	12.6		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BC01261

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	3.62		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01261**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	11.7		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	18.0		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYATT HOUSE
101 CORPORATE PARK AVE
HARRISON, NY

Received By : AO JR
Bottle No : T946 K1726 27 28 FB0352

Collection Point : SAMPLE STATION

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 10:38:00
Submitted On : 01/22/2026 AT 11:44:00

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.40
Free Cl2 : 0.91 Residual Cl2 :

Sample chilled on arrival ? : YES

add'l Report To :

Sample Type : POT_DW

Comment : 1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	1.93		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	12.4		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC01262**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	6.43		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. BC01262

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dichloroacetic Acid	11.2		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re\	Trichloroacetic Acid	15.3		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
 NYS ELAP # 10108
 (914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #6001
1490 OLD ORCHARD
W. HARRISON, NY

Received By : AO JR
Bottle No : T918 K1798 99 1800 FB0352

Collection Point : HYDRANT
ID of Source : NYC

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 11:20:00
Submitted On : 01/22/2026 AT 11:44:00

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.30
Free Cl2 : 0.27 Residual Cl2 :

addtl Report To :

Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment : TEMP: 5.8
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	2.59		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	18.0		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC01259**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01259**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

This sample had a pH of 3. The method stipulated preservation requirement is a pH <2. This method deviation will render the data unsuitable for regulatory reporting purposes.

DN/GZ/RH 2/5/26

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dichloroacetic Acid	10.6		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re\	Trichloroacetic Acid	22.2		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
 NYS ELAP # 10108
 (914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3885
 2 LINCOLN AVE
 HARRISON, NY

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
 1625 Mamaroneck Avenue
 Mamaroneck, NY 10543
 Attn: Frank Arcara

Received By : AO JR
 Bottle No : T6514 K1792 93 94 FB0352

Collected By : GIRILLO
 Collection Date : 01/22/2026 AT 09:15:00
 Submitted On : 01/22/2026 AT 11:44:00
 PWS No. : 5903435
 Type Descriptor : 022 Source ID : 000
 pH : 7.40
 Free Cl2 : 0.91 Residual Cl2 :
 Sample chilled on arrival ? : YES
 Sample Type : POT_DW
 Comment : TEMP: 5.2
 1ST QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	2.09		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	12.8		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
 NYS ELAP # 10108
 (914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BC01266

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01266**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	10.3		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	17.9		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : PURCHASE BOOSTER
4195 PURCHASE ST
HARRISON, NY

Received By : AO JR
Bottle No : T867 K1906 07 08 FB0352

Collection Point : ENTRY POINT

ID of Source : NYC

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 07:00:00
Submitted On : 01/22/2026 AT 11:44:00

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.33
Free Cl2 : 1.06 Residual Cl2 :

addtl Report To :

Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment :TEMP: 4.5
TURB: .67

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	1.23		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	6.92		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC01264**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01264**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	8.79		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	11.4		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : STAPLES
2444 BOSTON POST RD
LARCHMONT, NY

Received By : AO JR
Bottle No : T789 K1148 49 50 FB0352

Collection Point : SAMPLE STATION
ID of Source : NYC

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 08:25:00
Submitted On : 01/22/2026 AT 11:44:00

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.40
Free Cl2 : 0.63 Residual Cl2 :
Sample chilled on arrival ? : YES

add't'l Report To :

Sample Type : POT_DW
Comment : TEMP; 5.2
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	1.78		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	*THM-Chloroform	9.68		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BC01265

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01265**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	11.2		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	13.4		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3179
66 BELLEVUE AVE
HARRISON, NY

Received By : AO JR
Bottle No : T991 K1789 90 91 FB0352

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 08:55:00
Submitted On : 01/22/2026 AT 11:44:00

PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.30

Free Cl2 : 0.74 **Residual Cl2 :**

Sample chilled on arrival ? : YES

Sample Type : POT_DW

Comment : TEMP: 5.7
1ST QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	2.03		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	13.0		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BC01267

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
 NYS ELAP # 10108
 (914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01267**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	11.7		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	17.4		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3