

**Report for the First Quarter of 2026 pursuant to the Consent Decree entered in
United States v. Westchester Joint Water Works, 24 Civ. 4783 (S.D.N.Y.)**

This report summarizes the work undertaken to comply with the consent decree from January 1, 2026 through March 31, 2026 and provides the information required by paragraphs 70 and 71 of the consent decree.

The following are actionable items, relative to paragraph 71.a:

VII. INJUNCTIVE RELIEF: FILTRATION PLANT

23. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

24. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

25. Subject to Paragraph 33 and Section XIII (Force Majeure), by March 8, 2025, WJWW shall secure all necessary local, state, and federal final approvals and permits (excluding NYSDOH approvals and the Contractor Permits) for the Filtration Plant....

Compliance previously satisfied and described in Report for the First Quarter of 2025.

The following should be noted:

- As noted in previous reports, because the project site is a portion of DEC Site ID No. C360174 (HPN) under a Brownfield Cleanup Agreement (“BCA”) to which the County of Westchester (“County”) is a Participant under ECL 27-1405(1)(a), WJWW is coordinating with the Division of Environmental Remediation of the New York State Department of Environmental Conservation (“DEC Remediation”) regarding the proposed change of use. On a previous quarterly report, it was noted that on August 26, 2025, DEC Remediation accepted the Interim Remedial Measure (“IRM”) Work Plan, prepared by GZA GeoEnvironmental (“GZA”) for Hazen for the Rye Lake Water Filtration Plant (“WFP”) project. Following satisfactory results of soil, groundwater, and soil vapor sampling performed in accordance with the IRM Work Plan, DEC Remediation allowed the limited preliminary site work to begin, and YCC began this site work on November 20, 2025. The IRM Work Plan was prepared to allow for a Supplemental Remedial Investigation (“SRI”), remediation, and construction of the WFP. The IRM includes details about the procedures and requirements of the SRI. This SRI was needed to investigate the soil at the Rye Lake WFP site, since it was not investigated previously by the County under the BCP work to date. GZA completed the SRI Report (“SRIR”) in September 2025 which was submitted to the DEC on October 22, 2025. On October 30, 2025, the DEC met with YCC, GZA, and Hazen for the “IRM - Pre-

Construction Kickoff Meeting with DEC.” The DEC noted that they were reviewing the full SRIR, but based on the sampling outcomes, remedial efforts could move ahead on the property. On December 18, 2025, the DEC provided comments on the SRIR, and GZA responded to the comments on December 24, 2025. **The revised SRIR was approved by the DEC on March 26, 2026.** It should be emphasized that site work did continue in accordance with YCC’s proposed construction schedule while awaiting final approval of the SRIR.

- On November 5, 2025, following the Consent Decree quarterly report submitted on October 15, 2025, the DEC Division of Environmental Permits (“DEC Permits”) informed WJWW and Hazen that no ground disturbance at the WFP project site could begin until a Water Withdrawal Non-Public permit and a State Pollutant Discharge Elimination System (“SPDES”) permit are obtained, and likely modification of the DEC Freshwater Wetlands permit issued on October 15, 2024. On October 30, 2025, Tri-State Civil Construction LLC, subcontracted by YCC to design and implement the construction of the dewatering system for the WFP project site, submitted applications for these permits to DEC Permits. In an email from Rebecca Crist, Deputy Permit Administrator, Division of Environmental Permits, NYSDEC, to Tri-State on November 5, 2025, in response to those applications, Ms. Crist indicated that “no ground disturbance for this (WJWW Rye Lake Water Filtration Plant) project may begin until these (Water Withdrawal and SPDES Discharge) permits are processed.” In response to Ms. Crist’s email, WJWW submitted a Request for Exception for Good Cause to Ms. Crist on November 26, 2025, for consideration to allow for non-dewatering site work to proceed while these permits were being processed by the DEC. On December 1, 2025, WJWW Counsel Lori Lee Dickson forwarded a copy of the Request for Exception letter as required by Section XVIII and XIII of the Consent Decree. On December 19, 2025, Ms. Crist responded and requested additional information that is needed before DEC can make a decision on WJWW’s request, and also provided Notice of Incomplete Application regarding permit applications submitted by Tri-State on October 30, 2025. On December 31, 2025, WJWW provided the additional information requested, and on January 9, 2026 Hazen responded to the Notice of Incomplete Application. **On February 19, 2026, the DEC granted WJWW’s Request for Exception for Good Cause allowing non-dewatering site work to proceed while Water Withdrawal and SPDES Discharge Permits, and modification of the Freshwater Wetland Permit previously issued, are being processed by the DEC. On March 27, 2026, the DEC provided comments on the Water Withdrawal and Freshwater Wetland applications with Hazen expected to respond to these comments this week.** Notwithstanding the foregoing, the limited preliminary site work noted above in accordance with the SRI work plan has been proceeding.

26. Compliance previously satisfied and described in Report for the First Quarter of 2025.

27. Compliance previously satisfied and described in Report for the Second Quarter of 2025.
28. Compliance previously satisfied and described in Report for the Third Quarter of 2025.
29. Compliance previously satisfied and described in Report for the Fourth Quarter of 2025.
34. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

VIII. INJUNCTIVE RELIEF: INTERIM MEASURES

43. WJWW shall remain in compliance with the TTHM and HAA5 monitoring requirements, methodology requirements, and reporting requirements of the Stage 2 DBPR.

WJWW continues to comply.

44. WJWW shall conduct monitoring quarterly for TTHM and HAA5 in accordance with 40 C.F.R. § 141.621(a) and WJWW's approved monitoring plan...

WJWW continues to comply.

45. WJWW must comply with all public notice requirements specified in 40 C.F.R. Part 141, Subpart Q, for any TTHM or HAA5 MCL violation that occurs after the Effective Date of this Consent Decree.

There have been no violations since the Effective Date of the Consent Decree.

46. In addition to routine reporting to the WCDOH, WJWW shall submit to EPA the results of the TTHM and HAA5 monitoring required by this subparagraph...

A copy of the 2026 1st Quarter TTHM and HAA5 Sampling Report previously provided to the WCDOH, under cover letter dated March 12, 2026, is annexed as Appendix A. These results have been posted on the WJWW Filtration Plant microsite <https://wjwwfiltration.org/>

47. If the WJWW Water System violates a TTHM or HAA5 MCL, WJWW must submit a report to EPA, WCDOH, and NYSDOH ...

There have been no violations since the Effective Date of the Consent Decree.

48. At all times after the Effective Date during the duration of this Decree, WJWW must implement the flushing protocol attached hereto as Appendix B...

The flushing protocol was implemented in 2020 and has continued uninterrupted to date and will continue.

50. Compliance previously satisfied and described in Report for the Fourth Quarter of 2025.

53. *CT Calculations.* For each day the WJWW water system is in operation, the WJWW shall calculate the total inactivation ratio pursuant to the provisions of 40 C.F.R. §§ 141.74(b)(3) and (4). WJWW shall report to EPA, NYSDOH, and WCDOH the information listed at 40 C.F.R. § 141.75(a)(2) monthly, within 10 Days after the end of each month.

Water System Operating Reports for January, February and March 2026, were submitted to the EPA and the NYSDOH on February 9, 2026, March 5, 2026, and April 8, 2026, and to the WCDOH on February 5, 2026, March 5, 2026, and April 7, 2026, respectively.

55. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

57. *WJWW shall include a statement in its annual Drinking Water Quality Report until compliance with the deadlines in Section VII is achieved...*

On May 30, 2025, the latest Annual Drinking Water Quality Report, which includes such statement, was posted on WJWW website: <https://www.wjww.com/>

58. *Prior to commencing construction of the Filtration Plant, WJWW shall establish and maintain a website or a webpage on its website...*

The required information is available to the public at the project website: <https://wjwwfiltration.org/>

60. Compliance previously satisfied and described in Report for the Fourth Quarter of 2025.

X. SUPPLEMENTAL ENVIRONMENTAL PROJECT

61. *WJWW shall implement a Supplemental Environmental Project ("SEP") in accordance with this Section X and the SEP Memo annexed as Appendix D. WJWW shall spend no less than \$900,000 to implement the SEP. The SEP shall be completed within 54 months after the Effective Date in accordance with the schedule of milestones set forth in Appendix D. The SEP shall be comprised of the project to improve the quality of storm water entering the Kensico Reservoir described in the SEP Memo annexed as Appendix D.*

On March 24, 2026, the WJWW Board of Trustees passed a Resolution for Authorization To Remit Stipulated Penalty In Lieu Of Completion Of Court-Ordered Supplemental Environmental Project.

VI. CIVIL PENALTY

17. In addition, WJWW shall spend a total of at least \$6,800,000 on two water quality benefit projects (the "Benefit Projects"). ... The Benefit Projects are: (i) a new water main to the Quarry Heights neighborhood of the Town of North Castle (the "Quarry Heights Project"), as described in Appendix A, and (ii) the establishment of a Lead Service Line Replacement Program (the "Lead Service Line Replacement Program").

- With regard to 17.a, WJWW has deposited \$1,100,000 into a segregated account to be used exclusively for the Quarry Heights Project.
- On May 19, 2025, WJWW deposited \$5,700,000 into a segregated account to be used exclusively for the Lead Service Line Replacement Program. On August 21, 2025, the proposed Lead Service Line Replacement Program was approved by the State.

18. WJWW shall provide the State with an accounting of the amount spent on the Benefit Projects within 60 Days of project completion.

- Neither the Quarry Heights Project nor the Lead Service Line Replacement Program has been completed. It can be noted that the Quarry Heights Project is approximately 95% complete with the project now expected to be fully completed by Fall 2026.
- It can be noted that WJWW has expended approximately \$1,043,113 on the Quarry Heights Project to date, and has expended \$0 on the Lead Service Line Replacement Program to date.

I hope that the above provides a satisfactory Quarterly Report. Should you require any additional information, details or clarification, please let me know.

73. Certification

I certify under penalty of perjury that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the

information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I have no personal knowledge that the information submitted is other than true, accurate, and complete. I am aware that there are significant penalties for knowingly submitting false information, including the possibility of fine and imprisonment for knowing violations.

Dated: April 13, 2026



Paul Kutzy, P.E.
Manager
Westchester Joint Water Works
1625 Mamaroneck Ave.
Mamaroneck, NY 10543
Office: 914-698-3500 x 612
Fax: 914-381-4241
pkutzy@wjww.com

APPENDIX A

2026 Q1 TTHM & HAA5 Sampling Report



WESTCHESTER JOINT WATER WORKS

1625 Mamaroneck Avenue
Mamaroneck, New York 10543
www.wjww.com

Telephone: (914) 698-3500
Fax: (914) 381-4241
Fax: (914) 381-0349

March 12, 2026

Ms. Tucker
Assistant Engineer
Bureau of Environmental Quality
Westchester County Department of Health
11 Martine Ave
White Plains, NY 10606

Dear Ms. Tucker,

I have attached the Westchester Joint Water Works 2026 1st quarter THM and HAA5 results.

If you have any questions, please don't hesitate to contact me. Thank you.

Very truly yours,

Daniel Pirrone
Chief Water Treatment Pl. Operator IB

**Bureau of Environmental Quality
Public Water Supply Stage II Haloacetic Acids (HAA5) Sampling Report**

Westchester Joint Water Works
Name of Public Water Supply

2026
1st Quarter Period

Date of Sampling: 1/22/2026
Time of Sampling: 0700 Through 1120

Haloacetic Acids (HAA5)	Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Dibromoacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////	////	////	////	////	////	////	////
Dichloroacetic Acid (ug/L)	14.40	11.70	11.20	10.60	10.30	8.79	1.78	11.70	////	////	////	////	////	////	////	////
Monochloroacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////	////	////	////	////	////	////	////
Trichloroacetic Acid (ug/L)	28.60	18.00	15.30	22.20	17.90	11.40	9.68	17.40	////	////	////	////	////	////	////	////
Monobromoacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	////	////	////	////	////	////	////	////
									////	////	////	////	////	////	////	////
Total Haloacetic Acids (ug/L)	43.000	29.700	26.500	32.800	28.200	20.190	11.460	29.100								
Total Haloacetic Acids (mg/L)	0.043	0.030	0.027	0.033	0.028	0.020	0.011	0.029								

Sampling Location #	Address of Sampling Location / (Sample Collection Point)	1st Quarter 2026		4th Quarter 2025	3rd Quarter 2025	2nd Quarter 2025	Current Four Quarter Rolling Average	
		Cl2 Residual (mg/L)	HAA5 (mg/L)	HAA5 (mg/L)	HAA5 (mg/L)	HAA5 (mg/L)	HAA5 (mg/L)	
1	250 Westchester Ave (Hydrant P-14)		0.43	0.043	0.028	0.031	0.042	0.036
2	12 Beverly Rd (Hydrant No. 3577)		0.84	0.030	0.032	0.033	0.045	0.035
3	Hyatt House 101 Corporate Park Drive (Kitchen Sink)		0.91	0.027	0.032	0.004	0.040	0.026
4	1490 Old Orchard Rd (Hydrant No. 6001)		0.27	0.033	0.027	0.029	0.018	0.027
5	2 Lincoln Lane (Hydrant No. 3883)		0.91	0.028	0.036	0.043	0.042	0.037
6	Booster Station 4195 Purchase St (Lab Sink)		1.06	0.020	0.022	0.004	0.035	0.020
7	Staples Boston Post Rd (Bathroom Sink)		0.63	0.011	0.027	0.033	0.037	0.027
8	66 Bellevue Ave (Hydrant No. 3179)		0.74	0.029	0.042	0.028	0.048	0.037
Lab Performing Analysis: Westchester County Dept of Labs Samples Approved 3/9/2026							Rolling Average MCL: 0.06 mg/L	

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #P-14
250 WESTCHESTER AVE
W. HARRISON NY

Received By : AO JR
Bottle No : T6910 K1654 55 56 FB0352

Collection Point : HYDRANT

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 10:50:00
Submitted On : 01/22/2026 AT 11:44:00

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.30
Free Cl2 : 0.43 Residual Cl2 :

Sample chilled on arrival ? : YES

add'l Report To :

Sample Type : POT_DW

Comment : TEMP: 5.0
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	3.05		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	23.4		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BC01260

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	3.02		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01260**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	1.01		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dichloroacetic Acid	14.4		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re\	Trichloroacetic Acid	28.6		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3577
12 BEVERLY RD
HARRISON, NY

Received By : AO JR
Bottle No : T922 K1705 06 07 FB0352

Collection Point : HYDRANT

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 10:15:00
Submitted On : 01/22/2026 AT 11:44:00

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.60
Free Cl2 : 0.84 Residual Cl2 :

Sample chilled on arrival ? : YES

add'l Report To :

Sample Type : POT_DW

Comment : TEMP: 6.2
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	1.96		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	12.6		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. BC01261

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	3.62		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. BC01261

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	11.7		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	18.0		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYATT HOUSE
101 CORPORATE PARK AVE
HARRISON, NY

Received By : AO JR
Bottle No : T946 K1726 27 28 FB0352

Collection Point : SAMPLE STATION

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 10:38:00
Submitted On : 01/22/2026 AT 11:44:00

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.40
Free Cl2 : 0.91 **Residual Cl2 :**

Sample chilled on arrival ? : YES

add'l Report To :

Sample Type : POT_DW

Comment : 1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	1.93		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	12.4		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By Robert Hilbrandt Jr.

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. BC01262

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	6.43		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01262**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dichloroacetic Acid	11.2		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re\	Trichloroacetic Acid	15.3		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #6001
1490 OLD ORCHARD
W. HARRISON, NY

Received By : AO JR
Bottle No : T918 K1798 99 1800 FB0352

Collection Point : HYDRANT
ID of Source : NYC

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 11:20:00
Submitted On : 01/22/2026 AT 11:44:00

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.30
Free Cl2 : 0.27 Residual Cl2 :

Sample chilled on arrival ? : YES
Sample Type : POT_DW

addtl Report To :

Comment :TEMP: 5.8
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	2.59		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	18.0		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. **BC01259**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
 NYS ELAP # 10108
 (914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01259**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

This sample had a pH of 3. The method stipulated preservation requirement is a pH <2. This method deviation will render the data unsuitable for regulatory reporting purposes.

DN/GZ/RH 2/5/26

Haloacetic Acids

EPA 552.2, Re\	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Dichloroacetic Acid	10.6		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re\	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re\	Trichloroacetic Acid	22.2		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3885
 2 LINCOLN AVE
 HARRISON, NY

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
 1625 Mamaroneck Avenue
 Mamaroneck, NY 10543
 Attn: Frank Arcara

Received By : AO JR
Bottle No : T6514 K1792 93 94 FB0352

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 09:15:00
Submitted On : 01/22/2026 AT 11:44:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
 pH : 7.40
 Free Cl2 : 0.91 **Residual Cl2 :**
 Sample chilled on arrival ? : YES
 Sample Type : POT_DW
Comment : TEMP: 5.2
 1ST QUARTER

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	2.09		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	12.8		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
 NYS ELAP # 10108
 (914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. BC01266

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
 NYS ELAP # 10108
 (914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01266**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	10.3		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	17.9		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : PURCHASE BOOSTER
4195 PURCHASE ST
HARRISON, NY

Received By : AO JR
Bottle No : T867 K1906 07 08 FB0352

Collection Point : ENTRY POINT

ID of Source : NYC

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 07:00:00
Submitted On : 01/22/2026 AT 11:44:00

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.33
Free Cl2 : 1.06 Residual Cl2 :

addtl Report To :

Sample chilled on arrival ? : YES
Sample Type : POT_DW
Comment :TEMP: 4.5
TURB: .67

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	1.23		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	6.92		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. **BC01264**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01264**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	8.79		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	11.4		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : STAPLES
2444 BOSTON POST RD
LARCHMONT, NY

Received By : AO JR
Bottle No : T789 K1148 49 50 FB0352

Collection Point : SAMPLE STATION

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 08:25:00
Submitted On : 01/22/2026 AT 11:44:00

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000
pH : 7.40
Free Cl2 : 0.63 Residual Cl2 :

Sample chilled on arrival ? : YES

Sample Type : POT_DW

add't'l Report To :

Comment : TEMP; 5.2
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	1.78		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	*THM-Chloroform	9.68		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZZ

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BC01265

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01265**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	11.2		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	13.4		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : HYD #3179
66 BELLEVUE AVE
HARRISON, NY

Received By : AO JR
Bottle No : T991 K1789 90 91 FB0352

Collection Point : HYDRANT

ID of Source : NYC

Collected By : GIRILLO
Collection Date : 01/22/2026 AT 08:55:00
Submitted On : 01/22/2026 AT 11:44:00

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

PWS No. : 5903435
Type Descriptor : 022 Source ID : 000

pH : 7.30

Free Cl2 : 0.74 Residual Cl2 :

Sample chilled on arrival ? : YES

Sample Type : POT_DW

add'l Report To :

Comment : TEMP: 5.7
1ST QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Organics

Volatile Organic Compounds

EPA 524.2	*THM-Bromodichloromethane	2.03		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Chloroform	13.0		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 1 of 3

Sample No. BC01267

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Benzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Hexachlorobutadiene	< LOQ	CL	ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	01/29/2026	GZ2
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	01/29/2026	GZ2
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Styrene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Toluene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	01/29/2026	GZ2
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	01/29/2026	GZ2

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
 NYS ELAP # 10108
 (914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 2 of 3

Sample No. **BC01267**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

"CL" qualifier - this compound recovered below the acceptable QC criteria in the daily calibration check. Established low bias on <LOQ results renders the analytical data suspect.

DN 2/3/26

Haloacetic Acids

EPA 552.2, Re1	Bromochloroacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dibromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Dichloroacetic Acid	11.7		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monobromoacetic Acid	< LOQ		ug/L	1.00	02/04/2026	LIYA
EPA 552.2, Re1	Monochloroacetic Acid	< LOQ		ug/L	2.00	02/04/2026	LIYA
EPA 552.2, Re1	Trichloroacetic Acid	17.4		ug/L	1.00	02/04/2026	LIYA

DL = Detection Limit

LOQ = Limit of Quantitation

E=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt Jr.**

Chief of Env. Lab Services

Date Approved : 03/09/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 6931

EMAIL 3/9/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Page 3 of 3