Report for the Third Quarter of 2026 pursuant to the Consent Decree entered in United States v. Westchester Joint Water Works, 24 Civ. 4783 (S.D.N.Y.)

This report summarizes the work undertaken to comply with the consent decree from July 1, 2026 through September 30, 2026 and provides the information required by paragraphs 70 and 71 of the consent decree.

The construction status of the water filtration plant can be found on the project website under the "Construction" pulldown, then click on "Construction Status"
https://wjwwfiltration.org/

The following are actionable items, relative to paragraph 71.a:

VII. INJUNCTIVE RELIEF: FILTRATION PLANT

23. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

24. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

25. Subject to Paragraph 33 and Section XIII (Force Majeure), by March 8, 2025, WJWW shall secure all necessary local, state, and federal final approvals and permits (excluding NYSDOH approvals and the Contractor Permits) for the Filtration Plant....

Compliance previously satisfied and described in Report for the First Quarter of 2025.

The following should be noted:

- As noted and detailed in previous reports, on October 30, 2025, Tri-State Civil Construction LLC, subcontracted by Yonkers Contracting Company (YCC) to design and implement the construction of the dewatering system for the Water Filtration Plant (WFP) project site, submitted applications for a Water Withdrawal Non-Public permit and a State Pollutant Discharge Elimination System ("SPDES") permit to the DEC Division of Environmental Permits ("DEC Permits"). In an email from Rebecca Crist, Deputy Permit Administrator, Division of Environmental Permits, NYSDEC, to Tri-State on November 5, 2025, in response to those applications, Ms. Crist indicated that "no ground disturbance for this (WJWW Rye Lake Water Filtration Plant) project may begin until these (Water Withdrawal and SPDES Discharge) permits are processed." In response, WJWW submitted a Request for Exception for Good Cause to the DEC on November 26, 2025, for consideration to allow for non-dewatering site work to proceed while these permits were being processed by the DEC. On February 19, 2026, the DEC granted WJWW's Request for Exception for Good Cause allowing non-dewatering site work to proceed while Water Withdrawal and SPDES Discharge Permits, and also

modification of the Freshwater Wetland Permit previously issued, are being processed by the DEC. On March 27, 2026, the DEC provided comments on the Water Withdrawal and Freshwater Wetland permit applications, and Hazen subsequently responded to those comments. The DEC public comment period for these permit applications concluded on June 29, 2026 with no public comments received. **The DEC has completed processing these applications and issued Permits on July 17, 2026.**

26. Compliance previously satisfied and described in Report for the First Quarter of 2025.

27. Compliance previously satisfied and described in Report for the Second Quarter of 2025.

28. Compliance previously satisfied and described in Report for the Third Quarter of 2025.

29. Compliance previously satisfied and described in Report for the Fourth Quarter of 2025.

34. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

VIII. INJUNCTIVE RELIEF: INTERIM MEASURES

43. WJWW shall remain in compliance with the TTHM and HAA5 monitoring requirements, methodology requirements, and reporting requirements of the Stage 2 DBPR.

WJWW continues to comply.

44. WJWW shall conduct monitoring quarterly for TTHM and HAA5 in accordance with 40 C.F.R. § 141.621(a) and WJWW's approved monitoring plan...

WJWW continues to comply.

45. WJWW must comply with all public notice requirements specified in 40 C.F.R. Part 141, Subpart Q, for any TTHM or HAA5 MCL violation that occurs after the Effective Date of this Consent Decree.

There have been no violations since the Effective Date of the Consent Decree.

46. In addition to routine reporting to the WCDOH, WJWW shall submit to EPA the results of the TTHM and HAA5 monitoring required by this subparagraph...

A copy of the 2026 3rd Quarter TTHM and HAA5 Sampling Report previously provided to the WCDOH, under cover letter dated September 8, 2026, is annexed as Appendix A. These results have been posted on the WJWW Filtration Plant microsite https://wjwwfiltration.org/

47. If the WJWW Water System violates a TTHM or HAA5 MCL, WJWW must submit a report to EPA, WCDOH, and NYSDOH ...

There have been no violations since the Effective Date of the Consent Decree.

48. At all times after the Effective Date during the duration of this Decree, WJWW must implement the flushing protocol attached hereto as Appendix B...

The flushing protocol was implemented in 2020 and has continued uninterrupted to date and will continue.

50. Compliance previously satisfied and described in Report for the Fourth Quarter of 2025.

53. CT Calculations. For each day the WJWW water system is in operation, the WJWW shall calculate the total inactivation ratio pursuant to the provisions of 40 C.F.R. §§ 141.74(b)(3) and (4). WJWW shall report to EPA, NYSDOH, and WCDOH the information listed at 40 C.F.R. § 141.75(a)(2) monthly, within 10 Days after the end of each month.

Water System Operating Reports for July, August and September 2026, were submitted to the EPA and the NYSDOH on August 6, 2026, September 9, 2026, and October 7, 2026, and to the WCDOH on August 6, 2026, September 8, 2026, and October 7, 2026, respectively.

55. Compliance previously satisfied and described in Report for the Fourth Quarter of 2024.

57. WJWW shall include a statement in its annual Drinking Water Quality Report until compliance with the deadlines in Section VII is achieved...

On May 30, 2026, the latest Annual Drinking Water Quality Report, which includes such statement, was posted on WJWW website: https://www.wjww.com/

58. Prior to commencing construction of the Filtration Plant, WJWW shall establish and maintain a website or a webpage on its website...

The required information is available to the public at the project website: https://wjwwfiltration.org/

60. Compliance previously satisfied and described in Report for the Fourth Quarter of 2025.

X. SUPPLEMENTAL ENVIRONMENTAL PROJECT

61. Compliance previously satisfied and described in Report for the Second Quarter of 2026.

VI. CIVIL PENALTY

17. In addition, WJWW shall spend a total of at least $6,800,000 on two water quality benefit projects (the "Benefit Projects"). ... The Benefit Projects are: (i) a new water main to the Quarry Heights neighborhood of the Town of North Castle (the "Quarry Heights Project"), as described in Appendix A, and (ii) the establishment of a Lead Service Line Replacement Program (the "Lead Service Line Replacement Program").

- With regard to 17.a, WJWW has deposited $1,100,000 into a segregated account to be used exclusively for the Quarry Heights Project.

- On May 19, 2025, WJWW deposited $5,700,000 into a segregated account to be used exclusively for the Lead Service Line Replacement Program. On August 21, 2025, the proposed Lead Service Line Replacement Program was approved by the State.

18. WJWW shall provide the State with an accounting of the amount spent on the Benefit Projects within 60 Days of project completion.

- Neither the Quarry Heights Project nor the Lead Service Line Replacement Program has been completed. It can be noted that the Quarry Heights Project is approximately 95% complete with the project now expected to be fully completed by Fall 2026.

- It can be noted that WJWW has expended approximately $1,043,113 on the Quarry Heights Project to date, and has expended $0 on the Lead Service Line Replacement Program to date.

I hope that the above provides a satisfactory Quarterly Report. Should you require any additional information, details or clarification, please let me know.

73. Certification

I certify under penalty of perjury that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I have no personal knowledge that the information submitted is other than true, accurate, and complete. I am aware that there are significant penalties for knowingly submitting false information, including the possibility of fine and imprisonment for knowing violations.

Dated: October 8, 2026

Paul Kutzy, P.E.
Manager
Westchester Joint Water Works
1625 Mamaroneck Ave.
Mamaroneck, NY 10543
Office: 914-698-3500 x 612
Fax: 914-381-4241
pkutzy@wjww.com

APPENDIX A

2026 Q3 TTHM & HAA5
Sampling Report

WESTCHESTER JOINT WATER WORKS

1625 Mamaroneck Avenue
Mamaroneck, New York 10543
www.wjww.com

Telephone: (914) 698-3500
Fax: (914) 381-4241
Fax: (914) 381-0349

September 8, 2026

Ms. Tucker
Assistant Engineer
Bureau of Environmental Quality
Westchester County Department of Health
11 Martine Ave
White Plains, NY 10606

Dear Ms. Tucker,

I have attached the Westchester Joint Water Works 2026 3rd quarter THM and HAA5 results.

If you have any questions, don't hesitate to get in touch with me. Thank you.

Very truly yours,

Daniel Pirrone

Daniel Pirrone
Chief Water Treatment Pl. Operator IB

Bureau of Environmental Quality
Public Water Supply Stage II Trihalomethanes (THM) Sampling Report

Westchester Joint Water Works
Name of Public Water Supply

2026
3rd Quarter Period

Date of Sampling: 7/23/2026
Time of Sampling: 0650 Through 1000

Trihalomethanes (THM)	Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Bromodichloromethane (ug/L)	3.12	2.45	3.48	2.86	3.02	1.55	3.14	2.76								
Bromoform (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00								
Chloroform (ug/L)	26.70	18.80	24.00	25.20	27.50	11.00	25.00	23.40								
Dibromochloromethane(ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00								
Total Trihalomethanes (ug/L)	29.820	21.250	27.480	28.060	30.520	12.550	28.140	26.160								
Total Trihalomethanes (mg/L)	0.030	0.021	0.027	0.028	0.031	0.013	0.028	0.026								

Sampling Location #	Address of Sampling Location / (Sample Collection Point)	*3rd Quarter 2026*		*2nd Quarter 2026*	*1st Quarter 2026*	*4th Quarter 2025*	*Current Four Quarter Rolling Average*
		Cl2 Residual (mg/L)	*THM (mg/L)*	*THM (mg/L)*	*THM (mg/L)*	*THM (mg/L)*	*THM (mg/L)*
1	250 Westchester Ave (Hydrant P-14)	0.38	0.030	0.052	0.026	0.038	0.037
2	12 Beverly Rd (Hydrant No. 3577)	0.72	0.021	0.027	0.015	0.022	0.021
3	Hyatt House 101 Corporate Park Drive (Kitchen Sink)	0.24	0.027	0.031	0.014	0.026	0.025
4	1490 Old Orchard Rd (Hydrant No. 6001)	0.31	0.028	0.042	0.021	0.049	0.035
5	2 Lincoln Lane (Hydrant No. 3883)	0.61	0.031	0.030	0.015	0.030	0.027
6	Booster Station 4195 Purchase St (Lab Sink)	1.13	0.013	0.020	0.008	0.014	0.014
7	Staples Boston Post Rd (Bathroom Sink)	0.57	0.028	0.030	0.011	0.024	0.023
8	66 Bellevue Ave (Hydrant No. 3179)	0.61	0.026	0.041	0.015	0.035	0.029

Lab Performing Analysis: Westchester County Dept of Labs

Samples Approved 9/1/2026

Rolling Average MCL: 0.08 mg/L

Bureau of Environmental Quality
Public Water Supply Stage II Haloacetic Acids (HAA5) Sampling Report

Westchester Joint Water Works
Name of Public Water Supply

2026
3rd Quarter Period

Date of Sampling: 7/23/2026
Time of Sampling: 0650 Through 1000

Haloacetic Acids (HAA5)	Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations				Disinfection Station Sampling Locations			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Dibromoacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00								
Dichloroacetic Acid (ug/L)	3.66	10.60	4.98	6.81	10.60	9.76	13.40	10.90								
Monochloroacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00								
Trichloroacetic Acid (ug/L)	19.10	14.40	22.40	20.50	22.40	11.30	17.80	18.60								
Monobromoacetic Acid (ug/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00								
Total Haloacetic Acids (ug/L)	22.760	25.000	27.380	27.310	33.000	21.060	31.200	29.500								
Total Haloacetic Acids (mg/L)	0.023	0.025	0.027	0.027	0.033	0.021	0.031	0.030								

Sampling Location #	Address of Sampling Location / (Sample Collection Point)	Cl2 Residual (mg/L)	3rd Quarter 2026 HAA5 (mg/L)	2nd Quarter 2026 HAA5 (mg/L)	1st Quarter 2026 HAA5 (mg/L)	4th Quarter 2025 HAA5 (mg/L)	Current Four Quarter Rolling Average HAA5 (mg/L)
1	250 Westchester Ave (Hydrant P-14)	0.38	0.023	0.070	0.043	0.028	0.041
2	12 Beverly Rd (Hydrant No. 3577)	0.72	0.025	0.054	0.030	0.032	0.035
3	Hyatt House 101 Corporate Park Drive (Kitchen Sink)	0.24	0.027	0.054	0.027	0.032	0.035
4	1490 Old Orchard Rd (Hydrant No. 6001)	0.31	0.027	0.063	0.033	0.027	0.038
5	2 Lincoln Lane (Hydrant No. 3883)	0.61	0.033	0.050	0.028	0.036	0.037
6	Booster Station 4195 Purchase St (Lab Sink)	1.13	0.021	0.042	0.020	0.022	0.026
7	Staples Boston Post Rd (Bathroom Sink)	0.57	0.031	0.045	0.011	0.027	0.029
8	66 Bellevue Ave (Hydrant No. 3179)	0.61	0.030	0.069	0.029	0.042	0.043

Lab Performing Analysis: Westchester County Dept of Labs

Samples Approved 9/1/2026

Rolling Average MCL: 0.06 mg/L

Sample No.**BC12838**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research **10 Dana Road Valhalla, New York 10595**

Sample Location : HYD #P-14
250 WESTCHESTER AVE
W. HARRISON, NY

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

addt'l Report To :

Received By : JR
Bottle No : T0033 K1130 31 32 FB0229

Collected By : GIRILLO
Collection Date : 07/23/2026 AT 09:35:00
Submitted On : 07/23/2026 AT 10:03:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.38
Free Cl2 : 0.38 **mg/L**
Sample chilled on arrival ? : YES
Sample Type : POT_DW

Comment : TEMP: 19.2
3RD QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	3.12		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Chloroform	26.7		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12838**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Benzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/24/2026	LIYA
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Styrene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Toluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA

Haloacetic Acids

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12838**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 552.2, Rev	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dichloroacetic Acid	3.66		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/06/2026	LIYA
EPA 552.2, Rev	Trichloroacetic Acid	19.1		ug/L	1.00	08/06/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459 EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No.**BC12833**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research **10 Dana Road Valhalla, New York 10595**

Sample Location : HYD #3577
12 BEVERLY RD
HARRISON, NY

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

addt'l Report To :

Received By : JR
Bottle No : T971 K0864 65 66 FB0229

Collected By : GIRILLO
Collection Date : 07/23/2026 AT 07:10:00
Submitted On : 07/23/2026 AT 10:03:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.53
Free Cl2 : 0.72 **mg/L**
Sample chilled on arrival ? : YES
Sample Type : POT_DW

Comment : TEMP: 20.1
3RD QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	2.45		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Chloroform	18.8		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12833**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Benzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/24/2026	LIYA
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Styrene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Toluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA

Haloacetic Acids

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12833**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 552.2, Rev	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dichloroacetic Acid	10.6		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/06/2026	LIYA
EPA 552.2, Rev	Trichloroacetic Acid	14.4		ug/L	1.00	08/06/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459 EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No.**BC12835**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research **10 Dana Road Valhalla, New York 10595**

Sample Location : HYATT HOUSE
101 CORP PARK DIRVE
HARRISON, NY

Collection Point : SAMPLE STATION

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

addt'l Report To :

Received By : JR
Bottle No : T877 K1211 12 13 FB0229

Collected By : GIRILLO
Collection Date : 07/23/2026 AT 07:42:00
Submitted On : 07/23/2026 AT 10:03:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.53
Free Cl2 : 0.24 **mg/L**
Sample chilled on arrival ? : YES
Sample Type : POT_DW

Comment : TEMP: 20.4
3RD QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	3.48		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Chloroform	34.0		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12835**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Benzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/24/2026	LIYA
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Styrene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Toluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA

Haloacetic Acids

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12835**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 552.2, Rev	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dichloroacetic Acid	4.98		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/06/2026	LIYA
EPA 552.2, Rev	Trichloroacetic Acid	22.4		ug/L	1.00	08/06/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459 EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No.**BC12840**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research **10 Dana Road Valhalla, New York 10595**

Sample Location : HYD #6001
1490 OLD ORCHARD ST
W. HARRISON, NY

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

addt'l Report To :

Received By : JR
Bottle No : T855 K0843 44 45 FB0229

Collected By : GIRILLO
Collection Date : 07/23/2026 AT 10:00:00
Submitted On : 07/23/2026 AT 10:03:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.43
Free Cl2 : 0.31 **mg/L**
Sample chilled on arrival ? : YES
Sample Type : POT_DW

Comment : TEMP: 20.0
3RD QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	2.86		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Chloroform	25.2		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12840**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Benzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/24/2026	LIYA
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Styrene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Toluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA

Haloacetic Acids

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12840**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 552.2, Rev	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dichloroacetic Acid	6.81		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/06/2026	LIYA
EPA 552.2, Rev	Trichloroacetic Acid	20.5		ug/L	1.00	08/06/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459 EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No.**BC12839**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research **10 Dana Road Valhalla, New York 10595**

Sample Location : HYD #3883
2 LINCOLN AVE
HARRISON, NY

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

addt'l Report To :

Received By : JR
Bottle No : T618 K1226 27 28 FB0229

Collected By : GIRILLO
Collection Date : 07/23/2026 AT 06:50:00
Submitted On : 07/23/2026 AT 10:03:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.41
Free Cl2 : 0.67 **mg/L**
Sample chilled on arrival ? : YES
Sample Type : POT_DW

Comment : TEMP: 19.6
3RD QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	3.02		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Chloroform	27.5		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12839**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Benzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/24/2026	LIYA
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Styrene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Toluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA

Haloacetic Acids

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12839**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 552.2, Rev	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dichloroacetic Acid	10.6		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/06/2026	LIYA
EPA 552.2, Rev	Trichloroacetic Acid	22.4		ug/L	1.00	08/06/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459 EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No.**BC12834**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research **10 Dana Road Valhalla, New York 10595**

Sample Location : PURCHASE BOOSTER
4195 PURCHASE ST
HARRISON, NY

Collection Point : ENTRY POINT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

addt'l Report To :

Received By : JR
Bottle No : T892 K1223 24 25 FB0229

Collected By : GIRILLO
Collection Date : 07/23/2026 AT 07:20:00
Submitted On : 07/23/2026 AT 10:03:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.48
Free Cl2 : 1.13 **mg/L**
Sample chilled on arrival ? : YES
Sample Type : POT_DW

Comment : TEMP: 19.6
3RD QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	1.55		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Chloroform	11.0		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12834**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Benzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/24/2026	LIYA
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Styrene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Toluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA

Haloacetic Acids

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12834**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 552.2, Rev	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dichloroacetic Acid	9.76		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/06/2026	LIYA
EPA 552.2, Rev	Trichloroacetic Acid	11.3		ug/L	1.00	08/06/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459 EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No.**BC12837**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research **10 Dana Road Valhalla, New York 10595**

Sample Location : STAPLES
2444 BOSTON POST
LARCHMONT, NY

Collection Point : SAMPLE STATION

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

addt'l Report To :

Received By : JR
Bottle No : T0018 K0885 86 87 FB0229

Collected By : GIRILLO
Collection Date : 07/23/2026 AT 08:45:00
Submitted On : 07/23/2026 AT 10:03:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.38
Free Cl2 : 0.57 **mg/L**
Sample chilled on arrival ? : YES
Sample Type : POT_DW

Comment : TEMP: 19.7
3RD QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	3.14		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Chloroform	25.0		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12837**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Benzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/24/2026	LIYA
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Styrene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Toluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA

Haloacetic Acids

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12837**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 552.2, Rev	Bromochloroacetic Acid	1.13		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dichloroacetic Acid	13.4		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/06/2026	LIYA
EPA 552.2, Rev	Trichloroacetic Acid	17.8		ug/L	1.00	08/06/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459 EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No.**BC12836**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research **10 Dana Road Valhalla, New York 10595**

Sample Location : HYD #3179
66 BELLEVIEW AVE
HARRISON, NY

Collection Point : HYDRANT

ID of Source : NYC

Agency : Westchester Joint Water Works
1625 Mamaroneck Avenue
Mamaroneck, NY 10543
Attn: Frank Arcara

addt'l Report To :

Received By : JR
Bottle No : T6888 K1208 09 10 FB0229

Collected By : GIRILLO
Collection Date : 07/23/2026 AT 08:18:00
Submitted On : 07/23/2026 AT 10:03:00
PWS No. : 5903435
Type Descriptor : 022 **Source ID :** 000
pH : 7.44
Free Cl2 : 0.61 **mg/L**
Sample chilled on arrival ? : YES
Sample Type : POT_DW

Comment : TEMP: 19.6
3RD QUARTER

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Organics							
Volatile Organic Compounds							
EPA 524.2	*THM-Bromodichloromethane	2.76		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Bromoform	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Chloroform	23.4		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	*THM-Dibromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1- Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,1,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2,2-Tetrachloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1,2-Trichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,1-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,3-Trichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2,4-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3,5-Trimethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,3-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12836**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 524.2	1,3-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	1,4-Dichlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2,2-Dichloropropane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	2-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	4-Chlorotoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Benzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromochloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Bromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Carbon tetrachloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chlorobenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloroethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Chloromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	cis-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dibromomethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Dichlorodifluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Ethylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Hexachlorobutadiene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Isopropylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MEK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Methyl tert-butyl ether	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Methylene Chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	MIBK(not certified by NYSDOH)	< LOQ		ug/L	2.00	07/24/2026	LIYA
EPA 524.2	Naphthalene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	N-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	n-Propylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	o-Xylene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	p & m-Xylene	< LOQ		ug/L	1.00	07/24/2026	LIYA
EPA 524.2	p-Isopropyltoluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	sec-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Styrene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	tert-Butylbenzene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Tetrachloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Toluene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,2-Dichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	trans-1,3-Dichloropropene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichloroethene	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Trichlorofluoromethane	< LOQ		ug/L	0.50	07/24/2026	LIYA
EPA 524.2	Vinyl chloride	< LOQ		ug/L	0.50	07/24/2026	LIYA

Haloacetic Acids

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459

EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.

Sample No. **BC12836**

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
EPA 552.2, Rev	Bromochloroacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dibromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Dichloroacetic Acid	10.9		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monobromoacetic Acid	< LOQ		ug/L	1.00	08/06/2026	LIYA
EPA 552.2, Rev	Monochloroacetic Acid	< LOQ		ug/L	2.00	08/06/2026	LIYA
EPA 552.2, Rev	Trichloroacetic Acid	18.6		ug/L	1.00	08/06/2026	LIYA

DL = Detection Limit LOQ = Limit of Quantitation E=value is an estimate H = exceeds holding time

Approved By ***Robert Hilbrandt Jr.*** ***Chief of Env. Lab Services*** **Date Approved :** 09/01/2026

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 7459 EMAIL 9/1/2026

This report shall not be reproduced, except in full, without the written consent of the Westchester County Department of Labs and Research.